

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1341:102 Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Safetech International Inc, 13402 W. 92nd St., Lenexa, KS 66215  
Contact: Gaylen Davenport (913) 894-4855

**DESIGN:** Models IPB-3 and IPB-3NR indicating circuit power boosters. Power-limited, Style Y (Class B). Unit is intended to boost the power on an indicating device circuit of a separately listed fire alarm control unit. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Primary: 120 VAC, 1.0 A  
Secondary: 24 VDC battery

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Unit must provide the secondary power (battery back-up) for at least 24 hours as required per codes.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

**APPROVAL:** Listed as indicating circuit power booster for use with separately listed fire alarm control units.

03-14-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**